



Loyalsock Township Bus Garage Addition **G.C. ADDENDUM #1**

This Addendum forms a part of the Contract Documents and modifies the original Project Specifications and Drawings dated July 26th, 2016. Bidders shall carefully examine the Project Specifications for revised and updated items.

NOTE: Bidders must acknowledge receipt of this Addendum on their Bid Form.

Contractors should pay close attention to Scope of Work – 01 12 00 for the descriptions of each Prime Contract.

Just as a reminder - all bidders are responsible to do a complete review of the entire set of Contract Documents, and all issued Addenda.

The contract documents are amended as follows:

A. PROJECT CLARIFICATION:

1. Clarified Proper Address; 2101 Loyalsock Dr. (CV-1)
2. Gaps around fire barriers will receive "fire resistance joint system" (CV-2)
3. Construction type shall be 2B (CV-2)
4. Exit doors along Bay #1, 2, and 3 shall be new 90 min fire rated doors (A-3)
5. Braille exit signs shall be mounted at each exit door on latch side. (A-3)
6. Metal Roof Decking to be used in project shall be type B. (A-8, spec included)
7. New Parapet flashing shall be used over existing coping. (A-7, A-8)
8. 1-1/2" Rigid Insulation shall be installed over metal decking. (A-8)
9. 1-1/2" Rigid Insul. will be used along Parapet wall under roofing (A-7, A-8)
10. Roofing drainage pattern for addition (A-8, see note 7)

B. SPECIFICATION ALTERATIONS:

1. Section 05 31 00 Steel Roof Deck:

2.1 ROOF DECK

B. Steel Roof Deck

1. Type B Metal decking is 1-1/2" deep, 36" wide with nested side laps.





R A L

Architecture + Design, Inc.

This concludes Addendum #1

Please direct any additional questions to Robert Lack @ RAL Architecture + Design

570.524.2300 or rlack@ralad.com

