



Loyalsock Township Bus Garage Addition **G.C./E.C. ADDENDUM #3, August 3, 2016**

This Addendum forms a part of the Contract Documents and modifies the original Project Specifications and Drawings dated July 26th, 2016. Bidders shall carefully examine the Project Specifications for revised and updated items.

NOTE: Bidders must acknowledge receipt of this Addendum on their Bid Form. Contractors should pay close attention to Scope of Work – 01 12 00 for the descriptions of each Prime Contract.

Just as a reminder - all bidders are responsible to do a complete review of the entire set

A. SPECIFICATION Section 00 11 13, Advertisement for Bids,

1. Section 00 11 13, subsection **1.2 Bid submittal**
 1. Bid due date has been extended to Wednesday October 12, 2016, at 12:00 noon at the School District Business Office

The school district has encounter a few new details required in the land development permitting work requiring more time, for that reason the bid date is extended to Wednesday, October 12, 2016 at 12:00 noon.

As part of this addenda extending the bid due date until October 12, 2016, the School District will now need to require that all bids be guaranteed until spring, (March 2017). The School District anticipates a spring start, 2017, for this project given the delay in Land Development approval details.

2. Section 1.3 '**Bid Security**', shall be amended to read; **"No bids may be withdrawn for a period of 150 days, (thru March 12, 2017)"**

B. Clarification to drawing A-8, detail 1,

1. All new garage door openings on the east elevation will require two, (2) 7" x 4" x 3/4" new steel lintels supporting each opening, with 8" minimum bearing each end by GC. And masonry contractor is to securely attach all CMU work to steel frame, beam and roof framing with masonry ties.

This concludes Addendum #3

Please direct any additional questions to Robert Lack @ RAL Architecture + Design

570.524.2300 or rlack@ralad.com

