



3580 West Fourth Street
Williamsport, PA 17701-4107
Phone: 570-323-9889
Fax: 570-323-4291

March 25, 2015

**SHS HOSPITALITY INN /
DOOR HARDWARE RFI**

- > Door Hardware Set # 7.0 appears to call for a card reader to be used at Guestroom doors, but does not include any hardware item for it to activate. (The set only lists a standard mechanical lockset.) Is an electric strike required to be provided by the door and hardware supplier, and / or any related materials such as an in-line power controller, transformer, etc, or is the access control supplier handling any needs that are not specifically listed in the hardware set?

- > Door Hardware Sets # 8.0 & 8.1 call for a card reader with an electric latch retraction panic device. A Corbin 782 controller is required as power source for that type of device to maintain warranty, but no power supply is listed in the hardware set. A power transfer of some sort also should be needed to get electricity from the frame to the door & panic, such as a door cord or concealed power transfer, but none is noted in the set. Should these items be added to the set for inclusion by the door & hardware supplier?

- > The electric latch retraction panic device listed for Hardware Sets # 8.0 & 8.1 is a surface vertical rod model, less bottom rod. Since the openings involved are all just single 3/0 x 7/0 doors, could the rim panic model that is typically used in such situations be used instead?

Thanks,
Mike Adams
Estimator / Project Manager
Lezzer Commercial Door- Williamsport Division
570-323-9889 ph.
570-323-4291 fx.
mikeadams@lezzer.com